

Republic of the Philippines  
DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES  
*Office of the Regional Executive Director*  
Region XI, Lanang, Davao City

**REQUEST FOR QUOTATION**

Date : November 12, 2020

Quotation No : 20-11-454

Division/Section: PMD - RICTU

Company Name: \_\_\_\_\_  
Address \_\_\_\_\_

Please quote your lowest price on the item/s listed below, subject to the General Conditions on the last page, stating the shortest time of delivery and submit your quotation duly signed by your representative not later than \_\_\_\_\_ in the return envelope attached herewith.

MARY GRACE C. ABISIT  
Procurement Officer

- NOTE:**
- 1 ALL ENTRIES MUST BE TYPEWRITTEN
  - 2 DELIVERY PERIOD WITHIN \_\_\_\_\_ CALENDAR DAYS
  - 3 WARRANTY SHALL BE FOR A PERIOD OF SIX (6) MONTHS FOR SUPPLIES & MATERIALS ONE(1) YEAR FOR EQUIPMENT, FROM DATE OF ACCEPTANCE BY PROCURING ENTITY
  - 4 PRICE VALIDITY SHALL BE FOR A PERIOD OF \_\_\_\_\_ CALENDAR DAYS
  - 5 G-EPS REGISTRATION CERTIFICATE SHALL BE ATTACHED SUBMISSION OF THE QUOTATION (ON FILE)
  - 6 BIDDERS SHALL SUBMIT ORIGINAL BROCHURES SHOWING CERTIFICATIONS OF THE PRODUCT BEING OFFERED.

ITEM NO.	unit	ITEM & DESCRIPTION	QTY.	UNIT PRICE
	units	<b>Uninterruptible Power Supply</b>	<b>2</b>	
		- Includes installation		
		- 5 KVA		
		- With Warranty		

Brand and Model : \_\_\_\_\_  
Delivery Period: \_\_\_\_\_  
Warranty : \_\_\_\_\_  
Price Validity : \_\_\_\_\_

After having carefully read and accepted your General Conditions, I/We quote you on the item at the prices noted above.

\_\_\_\_\_  
Printed Name/Signature  
\_\_\_\_\_  
Tel.No./Cellphone No.  
e-mail address

## **SPECIFICATION OF UPS: (2 UNITS)**

**(To be attached to the PR of UPS)**

### **OUTPUT**

Max Configurable Power (Watts)	4.0kWatts / 5.0kVA
Output Voltage Note	Configurable for 220 : 230 or 240 nominal output voltage
Efficiency at Full Load	96.00%
Output Voltage Distortion	Less than 5 % at full load
Output Frequency (sync to mains)	47 - 53 Hz For 50 Hz nominal Sync to mains
Other Output Voltages	220, 240
Load Crest Factor	3:01
Topology	Line interactive
Waveform type	Sine wave
Transfer Time	2 ms typical : 4 ms maximum

### **INPUT**

Input voltage range for main operations	151 - 302 Adjustable, 160 - 286V
Battery type	VRLA
Typical recharge time	3hour(s)
Battery Charge Power (Watts)	542 Watts
Battery Volt-Amp-Hour Capacity	1632
Interface Port(s)	DB-9 RS-232, SmartSlot
Control panel	LED status display with on line : on battery : replace battery and overload indicators
Audible Alarm	Audible and visible alarms : configurable delays
Surge energy rating	480Joules
Filtering	Full time multi-pole noise filtering : 0.3% IEEE surge let-through

### **PHYSICAL**

Maximum Height	222MM, 22.2CM
Maximum Width	483MM, 48.3CM
Maximum Depth	660MM, 66.0CM
Net Weight	97.73KG
Audible noise at 1 meter from surface of unit	53.0dBA
Online thermal dissipation	430.0BTU/hr

### **CONFORMANCE**

Approvals	C-Tick, CE, EN 50091-1, EN 50091-2, GOST, GS Mark, VDE
Standard warranty	2 years repair or replace

### **SUSTAINABLE OFFER STATUS**

RoHS	Compliant
------	-----------

RFO # 20-11-454